

AGA CERTIFIED PRODUCT



Certificate Holder: **EUROGYR PTY LTD**
ABN/ACN No. (if applicable): **153 362 095**
Manufacturer: **LAMTEC GmbH and Co KG**
Agent (if applicable): **N/A**
Type of Component: **BURNER MANAGEMENT SYSTEM
INCORPORATING GAS/AIR RATIO CONTROL AND
OPTIONAL LEAKAGE DETECTION SYSTEM**
Model No. & Description: **LAMTEC
FA1, ETAMATIC, ETAMATIC S, ETAMATIC OEM,
ETAMATIC S OEM, FMS 4, FMS 5**

JAS-ANZ



(Refer www.aga.asn.au for more details)

For use with Continuous Operation Flame Sensors:

UV Type	IR Type:
FFS 05 UV-1	FFS 05
FFS 05 UV-1 Ex	FFS 05 Ex
FFS 05 UV-1 Ex-II	FFS 05 Ex-II
FFS 05 UV-2	FFS 05-1
FFS 05 UV-2 Ex	FFS 05-1 Ex
FFS 05 UV-2 Ex-II	FFS 05-1 Ex-II
FFS 05 UV-3	FFS 06
FFS 05 UV-3 Ex	FLS 09
FFS 05 UV-4	F 200 K(1,2)...
FFS 05 UV-4 Ex	F 200 K2...Ex
FFS 06-UV	F 200 K2...Ex-II
FLS 09-UV	
F 200 K(1,2)...	
F 200 K2...Ex	
F 200 K2...Ex-II	

Relevant Standard(s): **EN298:2003
AS 4625-2008
AS 4630-2005**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Reviewing Officer

Certificate Authorised

Certificate first issued: **31 October 2008**

Certificate No:

7405

This copy valid from: **2 November 2011**

Refer specification issue:

04