



Industrie Service

Choose certainty.
Add value.

CONFIRMATION

on the examination of an independent flame detector device
according to DIN EN 298 and DIN EN 61508

Date: 2015-04-20

Our reference:
IS-TAF-MUC/ku

Order no. 2221691

Document:
CF15280015_BST_SIL.doc

Test Laboratory TÜV SÜD Industrie Service GmbH
Abteilung Feuerungs- und Wärmetechnik
Prüfbereich Sicherheits-, Kontroll-
und Regeleinrichtungen

Page 1

Subject of Test Type **F130I**

Ordering Company LAMTEC Leipzig GmbH & Co. KG
D-04425 Taucha

Product description Independent flame detector device
with UV flame sensor, or
with visible light flame sensor, or
with ionisation flame sensor

The document consists of
2 pages

Basis of Test DIN EN 61508:2011-02 parts 1-7,
DIN EN 298:2012-11

Excerpts from this document
may only be reproduced and
used for advertising purposes
with the express written
approval of TÜV SÜD Industrie
Service GmbH.

Test Reports no. C-F 1528-00/15 dated 2015-04-20

The test results refer exclusively
to the units under test.

The results in detail, the evaluation of the results and the conclusions out of
the results are described in the above mentioned test report. Excerpts from
this test reports and from the test documentation are printed on the reverse.

Feuerungs- und Wärmetechnik

Klaus Kurth
Stellvertretender Leiter
Feuerungs- und Wärmetechnik





Industrie Service

Product description Flame detector device

Type designation **F130I**

Hardware version V1.0.0.0

Software version V1.0.0.0

The independent flame detector device is suitable for flame detection of burners and combustion systems for gaseous, liquid and pulverized solid fuels

- with permanent operation (only with ionisation flame sensor)
- with non-permanent operation.

The flame detector device fulfils the requirements of DIN EN 298:2012-11.

The control unit of the independent flame detector device also fulfils the requirements of DIN EN 61508: 2011-02 parts 1-7 (2nd ed.), for safety functions up to safety integrity level **SIL 3**. The following safety parameters have been determined:

Probability of a dangerous failure (high demand / continuous mode)	PFH_D	$4,9 \cdot 10^{-9}$ 1/h
Safe failure fraction	SFF	99,0 %
Average diagnostic coverage	DC_{AVG}	98,0 %

These parameters have been calculated under the assumption of a Mean Time to Restoration MTTR= 8 h and a Proof Test Interval T_1 = 10 years, which is equivalent to the specified life time of the flame detector device.

The control unit of the independent flame detector device is capable to be used as single device for safety instrumented functions (SIF) according to DIN EN 61511-1 up to safety integrity level **SIL 3**.

According to DIN EN ISO 13849-1:2008-12, table 4, the control unit of the independent flame detector device is capable to be used as single device for safety related control functions (SRCF) up to performance level **PL e**.

The control unit of the independent flame detector device also fulfils the requirements of DIN EN 50156-1, clause 10.5, for safety functions up to safety integrity level **SIL 3**.

Conditions

The conditions mentioned in test report no. C-F 1528-00/15 dated 2015-04-20 shall be considered during installation, commissioning and operation.

Note

The statements on SIL capability respectively PL capability as well as the calculation of probabilistic parameters are only related to the control unit of the independent flame detector device and do not include the UV flame sensors and the flame sensors for visible light.