

**electronic copy**



Industrie Service

**Choose certainty.  
Add value.**

## CONFIRMATION

**on the examination of a  
combustion products sensing device for CO/H<sub>2</sub> and O<sub>2</sub>**

Date: 2015-03-06

Our reference:  
IS-TAF-MUC/ku

Order no. 1771654

Document:  
C14900314\_BST.docx

Page 1

**Test Laboratory:** TÜV SÜD Industrie Service GmbH  
Abteilung Feuerungs- und Wärmetechnik  
DIN-/DVGW-Prüfstelle

**Subject of Test:** Combustion products sensing device  
for CO/H<sub>2</sub> and O<sub>2</sub>, consisting of  
Lambda Transmitter: **LT3F**  
Flue gas sensor (CPSE): **KS1D / KS1D-HT**

**Ordering Company:** LAMTEC Meß- und Regeltechnik  
für Feuerungen GmbH & Co KG  
D-69190 Walldorf

The document consists of  
2 pages

**Basis of Test:** DIN EN 16340:2014-10,  
DIN EN 61508:2011-02, parts 1 – 7 (**SIL 2**)


Excerpts from this document  
may only be reproduced and  
used for advertising purposes  
with the express written  
approval of TÜV SÜD Industrie  
Service GmbH.

**Test Report:** No. C 1490-03/14 dated 2015-03-06

The test results refer exclusively  
to the units under test.

The tests have been performed with positive results.  
The results in detail, the evaluation of the results and the conclusions out  
of the results are described in the above mentioned test report.  
Excerpts from this test report are printed on the reverse.


Feuerungs- und Wärmetechnik

  
Johannes Steiglechner



Headquarters: Munich  
Trade Register Munich HRB 96 869  
VAT ID No. DE129484218  
Information pursuant to Section 2(1)  
DL-InfoV (Germany) at  
[www.tuev-sued.com/imprint](http://www.tuev-sued.com/imprint)

Supervisory Board:  
Karsten Xander (Chairman)  
Board of Management:  
Ferdinand Neuwieser (CEO),  
Dr. Ulrich Klotz, Thomas Kainz

Telefon: +49 89 51 90 - 1027  
Telefax: +49 89 51 90 - 3307  
E-mail [feuerung@tuev-sued.de](mailto:feuerung@tuev-sued.de)  
[www.tuev-sued.de/is](http://www.tuev-sued.de/is)  


TÜV SÜD Industrie Service GmbH  
Feuerungs- und Wärmetechnik  
Ridlerstrasse 65  
80339 Munich  
Germany



The following flue gas sensors (CPSE) can be used:

| Model                         |     | KS1D   |          | KS1D-HT  |
|-------------------------------|-----|--|----------|----------|
| Type                          |     | 656R2000   | 656R2010 | 656R2015 |
| Maximum flue gas temperature  | °C  | 300  | 300      | 1200     |
| Maximum flue gas speed        | m/s | 6  | 2        | 10       |
| Measurement range of the CPSD |     | O <sub>2</sub> : 0 ... 21 Vol. %<br>CO <sub>e</sub> : 0 ... 1000 ppm (equivalent CO value)               |          |          |
| Accuracy of measurement       |     | O <sub>2</sub> : ± 5 % of the measured value, ≥ 0,3 Vol. %<br>CO <sub>e</sub> : 0 ... 1000 ppm, ≥ 20 ppm |          |          |

Under consideration of the conditions listed below the combustion products sensing device fulfils the requirements of DIN EN 16340:2014-10 and is capable to fulfil the applicable requirements of DIN EN 61508:2011-02 parts 1-7 (2<sup>nd</sup> ed.), for safety functions up to safety integrity level **SIL 2**.

In combination with burner management systems and/or fuel/air ratio control systems, e.g. type Etamatic, FMS, VMS, Burnertronic BT300, the combustion products sensing device is suitable to perform O<sub>2</sub> / CO control functions for gas and oil burning appliances.

For a combination of the Lambda Transmitter type LT3F with the flue gas sensor type KS1D / KS1D-HT the following safety parameters have been determined according to DIN EN 61508:

|  |                          |                                 |
|--|--------------------------|---------------------------------|
| Probability of a dangerous failure (high demand / continuous mode) | <b>PFH<sub>D</sub></b>   | <b>1,16·10<sup>-7</sup> 1/h</b> |
| Probability of a dangerous failure (low demand mode)               | <b>PFD<sub>AVG</sub></b> | <b>2,85·10<sup>-3</sup></b>     |
| Safe failure fraction  | <b>SFF</b>               | <b>94,4 %</b>                   |
| Average diagnostic coverage  | <b>DC<sub>AVG</sub></b>  | <b>91,1 %</b>                   |

These parameters have been calculated under the assumption of a Mean Time to Restoration MTTR= 8 hours, a Diagnostic Test Interval T<sub>2</sub>= 0,5 hours, and of the following Proof Test Intervals T<sub>1</sub> which are equivalent to the specified life time of the system components:  
 LT3F: T<sub>1</sub> = 10 years,  
 KS1D/KS1D-HT: T<sub>1</sub> = 3 years.

The failure rate of the safety related LSB communication (interference free O<sub>2</sub> transmission in two logical channels) can be neglected for calculating the total failure rate for the complete combustion control functions (including the burner management system or fuel/air ratio control system).

The following conditions shall be considered:

1. For the integration of the combustion products sensing device into the complete combustion control system the conditions and rules of document "LT3F\_Verwendungsregeln.doc" shall be considered.
2. Safety-related parameters shall be set in accordance with all requirements applicable to the controlled combustion system. Safety-related parameters shall be checked after commissioning by appropriate verification and validation measures.
3. In order to achieve a degree of protection IP54 for the enclosure of the combustion products sensing device appropriate cable glands shall be used.
4. Only devices which provide protective separation from hazardous live parts according to DIN EN 61140, e.g. by double or reinforced insulation according to DIN EN 60730-1 or DIN EN 61010-1 or DIN EN 60950-1, shall be connected to the CAN bus interface (terminals 71 ... 75, 77 and 78).
5. Adequate information about proper location, mounting, installation, putting into service, operation and maintenance of the combustion products sensing device shall be included into the installation and operating instructions of the appliance or combustion system in an official language of the country in which it is to be used.